

| Tank | Description | Capacity (gals) | Volume | Contents | Hazardous Substance? | Use | Notes |
|--------|---|-----------------|--|---|---|--------------|---|
| No. 2 | insulated bullet tank (36' x 6') | 30,400 | full; 1999 - 1' water & 3.5' of iron flakes | aqueous phase, organic phase, & solids; 1999 - water & iron flakes | benzene, chloroform, 1,2-DCA, PCE, & TCE tox exceedences | trap tank ? | other products may have been stored in these tanks in the past (1999) |
| No. 4 | steel bullet tank (25' x 7') ? | 28700 ? | 3' | oily water; 1999 - empty & dry ? | no (147 TPH) | ? | other products may have been stored in these tanks in the past (1999) |
| No. 6 | rectangular steel box tank (40' x 12' x 8') | 28,700 | full (like concrete); 1999 - 3/4 full | rust solids; 1999 - iron filings saturated with water | no (TPH 2,770) 1999- solids: 16.62 mg/kg Aroclor 1254 | ? | other products may have been stored in these tanks in the past (1999) |
| No. 10 | horizontal welded tank (14' x 6.5') | 3,400 | empty | none 1999 - empty & dry | NA | product tank | other products may have been stored in these tanks in the past (1999); product tanks are used interchangeable (1994) |
| No. 13 | horizontal welded tank (15' x 8') | 5,600 | 2.5' | oily sludge; 1999 - 1' sludge overlain by 1.5' liquid | benzene, 1,2-DCA, PCE, & TCE tox exceedences (TPH 743,000) 1999- solids: 13.5 mg/kg Aroclor 1254; 1,2-DCA, PCE, TCE, carbon tetrachloride, & VC tox exceedences | product tank | other products may have been stored in these tanks in the past (1999); product tanks are used interchangeable (1994) |
| No. 14 | steel bullet tank (32' x 8') | 10,000 | empty; 1999 - full | 2" rust solids; 1999 - not described | not analyzed; 1999 - non-haz | product tank | other products may have been stored in these tanks in the past (1999); product tanks are used interchangeable (1994) |
| No. 15 | verticle bolted tank (18.5' x 26') | 73,500 | 1/2 full; 1999 - 3' | oily sludge; - oily liquid | benzene tox exceedence (TPH > 99%) 1999 - 25 mg/L 1,2-DCA; 35 mg/L ethyl benzene; 30 mg/L chloroform; 50 mg/L isopropyl benzene; 90 mg/L naphthalene; 20 mg/L styrene; 135 mg/L PCE; 30 mg/L 1,1,1-TCA; 130 mg/L TCE | ? | other products may have been stored in these tanks in the past (1999) |
| No. 16 | horizontal welded tank (13' x 8') | 5,000 | full; 1999 - empty & dry | oily sludge | no (TPH > 99%) | product tank | other products may have been stored in these tanks in the past (1999); product tanks are used interchangeable (1994) |
| No. 17 | horizontal welded tank (14' x 7') | 4,000 | empty; 1999 - 4' | rust solids; 1999 - liquid | no (TPH 1,240) 1999 - 1,508,000 mg/L chloroform & 348,000 mg/L 1,1,1-TCA | product tank | other products may have been stored in these tanks in the past (1999); product tanks are used interchangeable (1994) |
| No. 18 | horizontal welded tank (20' x 5') | 3,000 | ? 1999 - full tank & no bottom sludge | light organic phase | chloroform, heptachlor tox exceedences (TPH 999,000) | product tank | other products may have been stored in these tanks in the past (1999); product tanks are used interchangeable (1994) |
| No. 19 | verticle bolted tank (18.5' x 26') | 73,500 | 4' | oily sludge 1999 - 4' of oil, sludge, water mixture | no (TPH 629,000) 1999 - 16,000 mg/L 1,2-DCA; 150 mg/L PCE; 350 mg/L TCE | ? | other products may have been stored in these tanks in the past (1999) |
| No. 21 | verticle bolted tank (18.5' x 26') | 73,500 | 3/4 full 1999 - 14' | oily water | benzene, chloroform, 1,2-DCA tox exceedences (TPH 780,000) | ? | other products may have been stored in these tanks in the past (1999) |

| | | | | | | | |
|---------|--------------------------------------|-------|----------------|--|---|----------------------|---|
| No. 22 | horizontal welded tank (21' x 7') | 5,000 | ? 1999 - 4' | oily sludge 1999 - liquid | no (TPH > 99%) - very low levels of several organics (< 0.2 mg/L) | 1999 product tank | other products may have been stored in these tanks in the past (1999); product tanks are used interchangeable (1994) |
| No. 23 | horizontal welded tank (6' x 4') | 500 | ? | appears to be diesel 1999 - diesel fuel | no (TPH > 99%) | fuel | other products may have been stored in these tanks in the past (1999) |
| No. 100 | ? | ? | empty | none | NA | ? | |